




Société par Actions Simplifiée
au capital de 15 745 984 €
RCS Nanterre B 408 363 174





L C I E



13 ANNEXE

14 ATTESTATION D'EXAMEN CE DE TYPE

LCIE 09 ATEX 3099

15 DESCRIPTION DE L'APPAREIL OU DU SYSTEME DE PROTECTION

Poste de commande

Type : BZC8050

Le poste de commande BZC8050 est un équipement électrique combinant des éléments antidéflagrants et de sécurité augmentée certifiés :

- Interrupteurs, type BK8050 : LCIE 09 ATEX 3096 U
- Indicateurs, type BD8050 : LCIE 09 ATEX 3098 U
- Boutons de contrôle, type BA8050 : LCIE 07 ATEX 0006 U

Paramètres spécifiques du ou des modes de protection concernés :

Tension : AC 415 V

Courant : 10 A

Le marquage doit être :

WAROM GROUP CO., LTD

Adresse : ...

Modèle : BZC8050-...

N° de fabrication : ...

Année de fabrication : ...

Ex II 2 G

Ex de IIC IP 54

LCIE 09 ATEX 3099

AVERTISSEMENT – NE PAS OUVRIR SOUS TENSION

L'appareil doit également comporter le marquage normalement prévu par les normes de construction qui le concerne.

16 DOCUMENTS DESCRIPTIFS

Dossier de certification N° « Instruction of BZC8050 Series Explosion-proof control station » du 20/10/2008.

Ce document comprend 13 rubriques (102 pages).

17 CONDITIONS SPECIALES POUR UNE UTILISATION SÛRE

Néant

18 EXIGENCES ESSENTIELLES DE SECURITE ET DE SANTE

Couvertes par les normes listées au point 9.

19 VERIFICATIONS ET ESSAIS INDIVIDUELS

Après câblage final, conformément à l'article 7 de la norme EN 60079-7 (2007)

20 CONDITIONS DE CERTIFICATION

Les détenteurs d'attestations d'examen CE de type doivent également satisfaire les exigences de contrôle de production telles que définies à l'article 8 de la directive 94/9/CE.

13 SCHEDULE

14 EC TYPE EXAMINATION CERTIFICATE

LCIE 09 ATEX 3099

15 DESCRIPTION OF EQUIPMENT OR PROTECTIVE SYSTEM

Explosion proof control station

Type : BZC8050

The BZC8050 control unit station is an electric equipment of combining certified flameproof and increased safety elements.

- switch, type BK8050 : LCIE 09 ATEX 3096 U
- Indicators, type BD8050 : LCIE 09 ATEX 3098 U
- Buttons, type BA8050 : LCIE 07 ATEX 0006 U

Specific parameters of the mode(s) of protection concerned :

Voltage : AC 415 V

Current : 10 A

The marking shall be :

WAROM GROUP CO., LTD

Address : ...

Model : BZC8050-...

Serial number : ...

Year of construction : ...

Ex II 2 G

Ex de IIC IP 54

LCIE 09 ATEX 3099

WARNING-DO NOT OPEN WHEN ENERGIZED

The equipment shall also bear the usual marking required by the manufacturing standards applying to such equipment.

16 DESCRIPTIVE DOCUMENTS

Certification file N° « Instruction of BZC8050 Series Explosion-proof control station » dated 20/10/2008.

This file includes 13 items (102 pages).

17 SPECIAL CONDITIONS FOR SAFE USE

None

18 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS

Covered by standards listed at 9.

19 ROUTINE VERIFICATIONS AND TESTS

When fully wired, according to clause 7 of EN 60079-7 (2007) standard

20 CONDITIONS OF CERTIFICATION

Holders of EC type examination certificates are also required to comply with the production control requirements defined in article 8 of directive 94/9/EC.